# **Power Relays**

#### Multi-pole Power Relay for Carrying and Switching Contactor Current Range of 40 A at 440 VAC

- 40 A can be carried and switched on each of 4 poles.
- Possible to reach a maximum load capacity of 160 A when using 4-pole parallel connections.
- EN 60947-4-1 certification for mirror contact mechanisms has been obtained by using a combination of the relay and auxiliary contact blocks.
- Typical applications: high current or high inrush power supplies, commercial and industrial.
- · RoHS compliant.





# **Model Number Structure**

# **■** Model Number Legend

## Relay with Auxiliary Contact Block

**G7Z-** □ **-** □ □

1. Relay Contact Configuration

4A: 4PST-NO

3A1B: 3PST-NO/SPST-NC 2A2B: DPST-NO/DPST-NC

2. Contact Configuration of Auxiliary Contacts

20: DPST-NO

11: SPST-NO/SPST-NC

02: DPST-NC

3. Contact Mechanism of Auxiliary Contacts

Z: Bifurcated crossbar contact

## **Auxiliary Contact Block**

G73Z- □ □

1. Contact Configuration of Auxiliary Contacts

20: DPST-NO

11: SPST-NO/SPST-NC

02: DPST-NC

2. Contact Mechanism of Auxiliary Contacts

Z: Bifurcated crossbar contact

## ■ Configuration

Structure Classification		Contact of	configuration	Screw terminals
		Relay Auxiliary Contact Block		(See notes 1 and 2)
Relay with Auxiliary Contact Block	4 poles +	4PST-NO	DPST-NO	G7Z-4A-20Z
-	2 poles		SPST-NO/SPST-NC	G7Z-4A-11Z
			DPST-NC	G7Z-4A-02Z
		3PST-NO/SPST-NC	DPST-NO	G7Z-3A1B-20Z
			SPST-NO/SPST-NC	G7Z-3A1B-11Z
			DPST-NC	G7Z-3A1B-02Z
		DPST-NO/DPST-NC	DPST-NO	G7Z-2A2B-20Z
			SPST-NO/SPST-NC	G7Z-2A2B-11Z
			DPST-NC	G7Z-2A2B-02Z
Auxiliary Contact Block	2 poles	_	DPST-NO	G73Z-20Z
			SPST-NO/SPST-NC	G73Z-11Z
			DPST-NC	G73Z-02Z

Note: 1. Relay contact terminals are M5, and the coil terminals are M3.5.

2. Auxiliary contact block terminals are M3.5.

# **Ordering Information**

# ■ Relay with Auxiliary Contact **Block**

## **Relay with Auxiliary Contact Block (for Screw Terminals**)

Con	tact configuration	Rated	Model	
Relay	Auxiliary contact block	voltage		
4PST-NO	DPST-NO	12, 24 VDC	G7Z-4A-20Z	
	SPST-NO/SPST-NC	12, 24 VDC	G7Z-4A-11Z	
	DPST-NC	12, 24 VDC	G7Z-4A-02Z	
3PST-NO/	DPST-NO	12, 24 VDC	G7Z-3A1B-20Z	
SPST-NC	SPST-NO/SPST-NC	12, 24 VDC	G7Z-3A1B-11Z	
	DPST-NC	12, 24 VDC	G7Z-3A1B-02Z	
DPST-NO/	DPST-NO	12, 24 VDC	G7Z-2A2B-20Z	
DPST-NC	SPST-NO/SPST-NC	12, 24 VDC	G7Z-2A2B-11Z	
	DPST-NC	12, 24 VDC	G7Z-2A2B-02Z	

# ■ Accessories (Order Separately)

## **Auxiliary Contact Block**

Contact configuration	Model
DPST-NO	G73Z-20Z
SPST-NO/SPST-NC	G73Z-11Z
DPST-NC	G73Z-02Z

# **Specifications**

# **■** Ratings

## **Coil Ratings**

Item	Rated current	Coil resistance	Must operate voltage	Must release voltage	Maximum voltage	Power consumption
Rated voltage			Per	centage of rated volt	age	
12 VDC	333 mA	39 Ω	75% max.	10% min.	110%	Approx. 3.7 W
24 VDC	154 mA	156 Ω				

- Note: 1. Rated current and coil resistance were measured at a coil temperature of 23°C with coil resistance of ±15%.
  - 2. Operating characteristics were measured at a coil temperature of 23°C.
  - 3. The maximum allowable voltage is the maximum value of the fluctuation range for the Relay coil operating power supply and was measured at an ambient temperature of 23°C. There is, however, no continuous allowance.

## **Contact Ratings**

#### Relay

	Model	G7Z-4A-□Z, G7Z-3A1B-□Z, G7Z-2A2B-□Z		
Item	Load	Resistive load	Inductive load cos \( \phi = 0.3 \)	Resistive load L/R = 1 ms
Contact structure		Double bre	ak	
Contact material		AgSnIn		
Rated load	NO	40 A at 440 VAC	22 A at 440 VAC	5 A at 110 VDC
	NC	25 A at 440 VAC	10 A at 440 VAC	5 A at 110 VDC
Rated carry	NO	40 A	22 A	5 A
current	NC	25 A	10 A	5 A
Maximum contact v	oltage	480 VAC 125 VDC		
Maximum contact	NO	40 A		
current	NC	25 A		
Maximum	NO	17,600 VA	9,680 VA	550 W
switching capacity	NC	11,000 VA	4,400 VA	550 W
Minimum load		2 A at 24 VDC		

Note: The ratings for the auxiliary contact block mounted on the G7Z are the same as those for the G73Z auxiliary contact block.

## **Auxiliary Contact Block**

Model	G73Z-20	Z, G73Z-11Z,	G73Z-02Z
Item Load	Resistive load	Inductive load cos \$\phi = 0.3\$	Resistive load L/R = 1 ms
Contact structure	Double bre	ak	
Contact material	AgSnIn + A	Ag Rotary	
Rated load	1 A at 440 VAC	0.5 A at 440 VAC	5 A at 110 VDC
Rated carry current	1 A		
Maximum contact voltage	480 VAC		125 VDC
Maximum contact current	1 A		
Maximum switching capacity	440 VA	220 VA	110 W
Minimum load	1 mA at 5 \	/DC	

## **■** Characteristics

	Classification	Relay (See note 6.)	Auxiliary contact block	
Item	Model	G7Z-4A-□Z, G7Z-3A1B-□Z, G7Z-2A2B-□Z	G73Z-20Z, G73Z-11Z, G73Z-02Z	
Contact resistance (See note 2.)		100 mΩ max.		
Operating time (See	note 3.)	50 ms max.		
Release time (See no	ote 3.)	50 ms max.		
Maximum operating	Mechanical	1,800 operations/h		
frequency	Rated load	1,200 operations/h		
Insulation resistance	e (See note 4.)	1,000 M $\Omega$ min.		
Dielectric strength	Between coil and contacts	4,000 VAC, 50/60 Hz for 1 min	_	
	Between contacts of different polarity	4,000 VAC, 50/60 Hz for 1 min		
	Between contacts of the same polarity	2,000 VAC, 50/60 Hz for 1 min		
Impulse withstand	Between coil and contacts	10 kV, 1.2 x 50 μs	_	
	Between contacts of different polarity	10 kV, 1.2 x 50 μs		
	Between contacts of the same polarity	4.5 kV, 1.2 x 50 μs		
Vibration resistance	Destruction	10 to 55 to 10 Hz, 0.5-mm single amplitude (1.0-mm double amplitude)		
	Malfunction	NO: 10 to 55 to 10 Hz, 0.5-mm single amplitu NC: 10 to 32 to 10 Hz, 0.5-mm single amplitu		
Shock resistance	Destruction	Screw mounting: 800 m/s², DIN Track mounting	ng: 500 m/s <sup>2</sup>	
	Malfunction	NO: 100 m/s <sup>2</sup> NO: 25 m/s <sup>2</sup>		
Endurance	Mechanical	1,000,000 operations min. (at 1,800 operation	ns/h, contact no load)	
	Electrical (See note 5.)	AC resistive load: 80,000 operations AC inductive load: 80,000 operations DC resistive load: 100,000 operations (at 1,20	00 operations/h, rated load)	
Minimum load		2 A at 24 VDC	1 mA at 5 VDC	
Ambient operating to	emperature	-25 to 60°C (with no icing or condensation)		
Ambient operating h	umidity	5% to 85%		
Weight		Approx. 330 g		

Note: 1. The above values are initial values.

- 2. The contact resistance for the Relay (G7Z) was measured with 1 A at 5 VDC using the voltage drop method. The contact resistance for the auxiliary contact block (G73Z) was measured with 0.1 A at 5 VDC using the voltage drop method.
- 3. The operate time was measured with the rated voltage imposed with any contact bounce ignored at the ambient temperature of 23°C.
- 4. The insulation resistance was measured with a 1,000-VDC megohmmeter applied to the same places as those used for checking the dielectric strength.
- 5. The electrical endurance was measured at an ambient temperature of 23°C.
- 6. The specifications for the auxiliary contact block mounted on the G7Z are the same as those for the G73Z auxiliary contact block.

# **■** Approved Standards

## UL Recognized (File No. E41643) - - Ambient Temp = 40°C

Model	Coil ratings	Contact ratings		Number of test operations
G7Z	12, 24 VDC	NO contact	40 A, 480 VAC, 60 Hz (Resistive)	80,000
			5 A, 120 VDC (Resistive)	100,000
			22 A, 480 VAC, 60 Hz (General Use)	100,000
			D300* (1-A current applied)	_
		NC contact	25 A, 480 VAC, 60 Hz (Resistive) 5 A, 120 VDC (Resistive) 10 A, 480 VAC, 60 Hz (General Use)	100,000
			D300* (1-A current applied)	_

Note: Auxiliary contact ratings

Model	Contact ratings		
G73Z	NO contact	D300 (1-A current applied)	
	NC contact		

CSA Certification by c us

#### EN Standard/TÜV Certification: EN 60947-4-1 (Certification No. R50079155)

Model	Coil ratings		Contact ratings
G7Z	12, 24 VDC	NO contact	AC-1: 40 A, 440 V, 50/60 Hz
			AC-3: 16 A, 440 V, 50/60 Hz
			DC-1: 5 A, 110 V
			*AC15: 0.5 A, 440 V, 50/60 Hz
			*DC13: 0.5 A, 110 V
		NC contact	AC-1: 25 A, 440 V, 50/60 Hz
			DC-1: 5 A, 110 V
			*AC15: 0.5 A, 440 V, 50/60 Hz
			*DC13: 0.5 A, 110 V
G73Z	_	NO contact	AC15: 0.5 A, 440 V, 50/60 Hz
		NC contact	DC13: 0.5 A, 110 V

Note: Auxiliary contact ratings


# **Connections**

# ■ Terminal Arrangement/Internal Connections


# **Relay with Auxiliary Contact Block**

Note: non-polarized coil.


G7Z-4A-20Z




G7Z-4A-11Z




G7Z-4A-02Z




G7Z-3A1B-20Z




G7Z-3A1B-11Z




G7Z-3A1B-02Z




G7Z-2A2B-20Z



G7Z-2A2B-11Z




G7Z-2A2B-02Z




# **Auxiliary Contact Block**


G73Z-20Z



G73Z-11Z



G73Z-02Z




# **Dimensions**

Note: All units are in millimeters unless otherwise indicated.


## Relay (12 VDC, 24 VDC) with Auxiliary Contact Block


4 Poles





Four, M3.5







Two, M3.5

Note: The dimensions are typical values.

# **Auxiliary Contact Block**








Note: The dimensions are typical values.

# **DIN Track Mounting Height**

## (when using the PFP-100N or PFP-50N mounting rail)



Note: The dimensions are typical values.



## **Precautions**

Be sure to read the common precautions provided in Best Control Devices Catalog Version 17 before using the Relay.

## —∠!\ WARNING -

Take measures to prevent contact with charged parts when using the Relay for high voltages.



### /!\ CAUTION

Do not touch the terminal section (charged parts) when power is being supplied.

Always use the Relay with terminal covers mounted. Contact with charged parts may result in electric shock.




Do not touch the Relay when power is being supplied or right after the power has been turned OFF. The hot surface may cause burn injury.




# ■ Precautions for Correct Use Installation


• Mount the G7Z with the coil terminal at the top.



• Do not use the Relay with the terminal screw surfaces facing down.




• To mount the Relay, secure M4 screws in two locations. Use a screw-tightening torque of 1.2 to 1.3 Nom.




• The Relay can be mounted directly on a mounting rail (PTP) or a DIN Track (EN 50022-35 x 7.5, 15). The Relay cannot be mounted, however, to some reinforced rails (e.g., those produced by Kameda Denki or Toyogiken).


- Mount the Relay sideways when it is mounted on a rail.
- Use End Plates (PFP-M) on both sides of the Relay to make sure that it is properly secured.



• Provide at least 5 mm of space between the sides and top of the Relay and nearby grounded metal surfaces.



• Provide at least 30 mm of space between Relays when two or more Relays are mounted in a row.




• The auxiliary contact block (G73Z) can be mounted on the Relay.

## **Mounting and Removal**

#### Mounting


Insert the tab on the auxiliary contact block into the groove on the Relay and press down until the hook on the auxiliary contact block catches in the mounting hole on the Relay.



#### Removing

Slide the auxiliary contact block, remove the auxiliary contact block tab from the groove on the Relay, and remove the auxiliary contact block hook from the Relay.


Be careful not to apply excessive force on the hook.




## Connecting

• Use round or open-end (Y-type) crimp terminals and connect the terminals with the appropriate tightening torque. Refer to the terminal section space in the following figure for the crimp terminal dimensions.


#### Relay Contacts (Unit: mm)



## Relay Coil



## **Auxiliary Contact Block**



• One crimp terminal can be used for the Relay contact section (M5 screw). Two crimp terminals can be connected for the coil terminal and auxiliary contact block.

#### **Recommended Crimp Terminals and Wire**

Location	Crimp terminals	Appropriate wire size
Contact	5.5-5	2.63 to 6.64 mm <sup>2</sup> (AWG12, 10)
section	8-5	6.64 to 10.52 mm <sup>2</sup> (AWG8)
Coil section	1.25-3.5	0.5 to 1.65 mm <sup>2</sup> (AWG20 to 16)

• Use the following tightening torque when tightening screws. Loose screws may result in fire caused by abnormal heat generated when the power is being supplied.

M5 screws: 2.0 to 2.2 N•m M3.5 screws: 0.8 to 0.9 Nem

· Allow suitable slack on leads when wiring, and do not subject the terminals to excessive force.


## **Microloads**

The G7Z is used for switching power loads, such as current carry for device power supplies and heater loads. Use an auxiliary contact block (G73Z) if microloads are required for signal applications and operation status feedback.

## Operating Coil

## (Internal Connections of Coils)

#### DC Coil




- If a transistor drives the G7Z, check the leakage current and connect a bleeder resistor if necessary.
- The must operate voltage is the minimum value for the Relay armature to operate and the contacts to turn ON. Therefore, fundamentally apply the rated voltage to the coils, taking into consideration the increases in coil resistance caused by voltage fluctuation and coil temperature rise.

## Mirror Contact Mechanism

By combining a Relay with an auxiliary contact block, all NC contacts of the auxiliary contact block will satisfy an impulse withstand voltage of more than 2.5 kV or maintain a gap of more than 0.5 mm when the coil is de-energized even if at least one NO contact (main contact) of the Relay is welded (according to EN 60947-4-1).

#### **Description of Mirror Contact Mechanism**



#### ALL DIMENSIONS SHOWN ARE IN MILLIMETERS.

To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.



#### Read and Understand This Catalog

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

#### Warranty and Limitations of Liability

#### WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

#### LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY.

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

#### **Application Considerations**

#### **SUITABILITY FOR USE**

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- · Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- · Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

#### PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

#### **Disclaimers**

#### **CHANGE IN SPECIFICATIONS**

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

#### **DIMENSIONS AND WEIGHTS**

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

#### PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

#### **ERRORS AND OMISSIONS**

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.



OMRON ELECTRONICS LLC • THE AMERICAS HEADQUARTERS • Schaumburg, IL USA • 847.843.7900 • 800.556.6766 • www.omron247.com

OMRON CANADA, INC. • HEAD OFFICE

Toronto, ON, Canada • 416.286.6465 • 866.986.6766 www.omron247.com

OMRON ELETRÔNICA DO BRASIL LTDA • HEAD OFFICE

São Paulo, SP, Brasil • 55.11.2101.6300 • www.omron.com.br

OMRON ELECTRONICS MEXICO SA DE CV • HEAD OFFICE

Apodaca, N.L. • 52.811.156.99.10 • 001.800.556.6766 • mela@omron.com

**OMRON ARGENTINA • SALES OFFICE** 

Cono Sur • 54.11.4783.5300

**OMRON CHILE • SALES OFFICE** Santiago • 56.9.9917.3920

OTHER OMRON LATIN AMERICA SALES

54.11.4783.5300

OMRON EUROPE B.V. Wegalaan 67-69, NL-2132 JD, Hoofddorp, The Netherlands. Tel: +31 (0) 23 568 13 00 Fax: +31 (0) 23 568 13 88 www.industrial.omron.eu

J160-E1-02

06/09

Note: Specifications are subject to change.

© 2010 Omron Electronics LLC