# **Total Counter/Time Counter (DIN 72 x 36)**

# H7HP

CSM\_H7HP\_DS\_E\_4\_2

# DIN 72 x 36-mm Total Counter/Time Counter with Easy-to-read Displays and Water and Oil Resistance Equivalent to IP66

- Large, easy-to-read displays: 15-mm-high characters for 6-digit models; 12-mm-high characters for 8-digit models.
- High-visibility, negative transmissive LCD display with built-in red LED backlight at low power consumption.
- IP66 with oil resistance and NEMA4 are achieved by unifying the front with the casing case and using oil-resistant materials and parts.
- · Compact (66 mm) body.
- Switch 6-digit models between total counter and time counter operation.
- Just change a switch setting for either an NPN or PNP input.
- Supports both external resetting and manual resetting.
- Finger-protection terminal block cover prevents electrical shock and conforms to VDE0106, Part 100.
- Safety standards: UL, CSA, EMC (EN 61326), CE Marking.





For the most recent information on models that have been certified for safety standards, refer to your OMRON website.

# **Model Number Structure**

# **■** Model Number Legend

H7HP-

1. Classification

A: Total counter/time counter

C: Total counter

2. Digits

None: 6 digits 8: 8 digits 3. Supply Voltage

None: 100 to 240 VAC D: 12 to 24 VDC

4. Case Color

None: Light gray (Munsell 5Y7/1)

B: Black

# **Ordering Information**

### ■ List of Models

Supply voltage	6-digit total counter/time counter		8-digit total counter	
	Light gray	Black	Light gray	Black
100 to 240 VAC	H7HP-A	H7HP-AB	H7HP-C8	H7HP-C8B
12 to 24 VDC	H7HP-AD	H7HP-ADB	H7HP-C8D	H7HP-C8DB

# **Specifications**

# **■** Ratings

Item		6-digit total counter/time counter		8-digit total counter	
		H7HP-A	H7HP-AD	H7HP-C8	H7HP-C8D
Rated supp	ly voltage	100 to 240 VAC (50/60 Hz)	12 to 24 VDC (see note 1)	100 to 240 VAC (50/60 Hz)	12 to 24 VDC (see note 1)
External po	xternal power supply 50 mA at 12 VDC			50 mA at 12 VDC	
Operating voltage range 85% to 110% of rated supply voltage					
Power cons	umption	100 to 240 VAC: 6.5 VA max. 12 to 24 VDC: 0.6 W max.			
Dimensions	3	72 x 36 x 66 mm (W x H x D)			
Mounting m	ethod	Flush mounting			
External co	nnections	Screw terminals			
Degree of p	protection Panel surface: IP66 with oil resistance, NEMA 4 (indoors). Panel surface only: IEC IP66. IEC IP66			P66. IEC IP66	
Display		7-segment, negative transm	nissive LCD (with red backlig	ıht)	
Digits		6 digits (15-mm-high charac	cters)	8 digits (12-mm-high characters)	
Function		Total counter/time counter (	selected via DIP switch)	Total counter	
Input mode		Up/down (individual) (total of (time counter)	wn (individual) (total counter), or accumulative counter)  Up/down (individual)		
Max. counting speeds 30 Hz or 5 kHz (selected via DIP switch)					
Counting range		-99999 to 999999		-9999999 to 99999999	
Time specification 0.1 to 99999.9 h/1 s to 99 h 59 min 59 s (selected via DIP switch)					
Timing accuracy		±100 ppm (-10°C to 55°C)			
Memory bad	mory backup EEP-ROM (overwrites: 200,000 times min.) that can s		· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	
Input	Input signals	Count 1/start, count 2/gate, reset, and key protection (see note 2)			
	Input method	No-voltage input (NPN transistor input) or voltage input (PNP transistor input) (selected via DIP switch)			
	Count, start, gate, reset				
		Voltage input (PNP transistor Short-circuit (ON) impedation ON voltage: OFF voltage: Open (OFF) impedance:			
	Key protection	No-voltage input (NPN trans Short-circuit (ON) impeda Short-circuit (ON) residua Open (OFF) impedance:	ance: $1 \text{ k}\Omega$ max.		
Input re- Reset Time counter: 20 ms; total counter: 20		counter: 20 ms or 1 ms (auto	omatically switched according	g to counting speed)	
sponse	Start	Time counter: 20 ms			
speed	Key protection	Approx. 1 s		Approx. 1 s	
Reset system External and manual resets					

Note: 1. Contains 20% ripple (p-p) max.

<sup>2.</sup> Only a non-voltage input (NPN transistor) is possible for the key protection input. The key protection input will be a non-voltage input even if the NPN/PNP input mode is set to PNP. Key protection is used to prohibit operating the Reset Key. The reset input terminals will still be functional.

# **■** Characteristics

Insulation resistance	100 MΩ min. (at 500 VDC)		
Dielectric strength	2,000 VAC, 50/60 Hz for 1 min between current-carrying terminal and exposed non-current-carrying metal parts (AC model) 1,000 VAC, 50/60 Hz for 1 min between current-carrying terminal and exposed non-current-carrying metal parts (DC model) 2,000 VAC, 50/60 Hz for 1 min between power terminals and control input terminals (AC model)		
Impulse withstand voltage	3 kV (between power terminals) (1 kV for 12-to-24-VDC models) 4.5 kV (between current-carrying terminal and exposed non-current-carrying metal parts) (1.5 kV for 12-to-24-VDC models)		
Noise immunity	±1.5 kV (between AC power terminals), ±480 V (between DC power terminals), ±480 V (between input terminals); square-wave noise by noise simulator (pulse width: 100 ns/1 μs, 1-ns rise)		
Static immunity	Display: Malfunction: 8 kV Destruction: 15 kV  DIP switch: Malfunction: 4 kV Destruction: 8 kV		
Vibration resistance	Destruction: 10 to 55 Hz with 0.75-mm single amplitude, 2 hours each in three directions Malfunction: 10 to 55 Hz with 0.5-mm single amplitude, 10 minutes each in three directions		
Shock resistance	Destruction: 294 m/s <sup>2</sup> each in three directions Malfunction: 196 m/s <sup>2</sup> each in three directions		
Ambient temperature	Operating: -10°C to 55°C (with no icing) Storage: -25°C to 65°C (with no icing)		
Ambient humidity	Operating: 35% to 85%		
EMC	Emission Enclosure: Emission AC Mains: (EMS) Immunity ESD: Immunity RF-interference: Immunity Conducted Disturbance: Immunity Burst: Immunity Surge:	E61326 EN55011 Group 1 class A EN55011 Group 1 class A EN61326 EN61000-4-2: 4 kV contact discharge (level 2) 8 kV air discharge (level 3) EN61000-4-3: 10 V/m (Amplitude-modulated, 80 MHz to 1 GHz) (level 3); 10 V/m (Pulse-modulated, 900 MHz ±5 MHz) (level 3); EN61000-4-6: 10 V (0.15 to 80 MHz) (according to EN61000-6-2) EN61000-4-4: 2 kV power-line (level 3); 2 kV I/O signal-line (level 4) EN61000-4-5: 1 kV line to lines (power and output lines) (level 2); 2 kV line to ground (power and output lines) (level 3) EN61000-4-11: 0.5 cycle, 100% (rated voltage)	
Approved standards	UL508, CSA22.2 No.14, conforms to EN61010-1, VDE0106/P100		
Case color	Rear section: Gray smoke; Front section: 5Y7/1 (light gray) or N1.5 (black)		
Weight	Approx. 115 g		

# **Connections**


# **■** Terminal Arrangement

Note: 1. Incremented for count 1 (CP1) inputs; decremented for count 2 (CP2) inputs.


2. Non-contact input is also available.

### **AC Models**


#### H7HP-A




#### H7HP-C8



# DC Models H7HP-AD



#### H7HP-C8D



# **Operation**

# ■ DIP Switch Settings

Switches 1 to 4 are all set to OFF before shipping.



### H7HP-A□

Pin no.	Item	OFF	ON
1	Function	Total counter	Time counter
2	Counting speed (note)	30 Hz	5 kHz
	Time range (note)	99999.9 h	99 h 59 min 59 s
3	Input mode (note)	NPN	PNP
4	Unused		


# H7HP-C□

Pin no.	Item	OFF	ON
1	Unused		
2	Counting speed (note)	30 Hz	5 kHz
3	Input mode (note)	NPN	PNP
4	Unused		

Note: When the setting has been changed, turned power off and on to continue. The display will show "0" when the power is turned back on.

# **■** Operating Modes


### **Total Counters**



Note: Display values are shown for a 6-digit model.

The count value will return to "0" when "999999" is exceeded.


The display and output are turned OFF when the power supply turns OFF, but the count value is stored internally.




\* Display values are shown for full scale set to 99999.9 h.

Note: The count value will return to "0" when "99999.9" is exceeded. The display and output are turned OFF when the power supply turns OFF, but the count value is stored internally.

# **Nomenclature**





(The figure shows the DIP switch label stuck to the rear of the case.)

1. Reset Key

Resets the count value, but will not operate while the keys are protected.

2. Key Protection Indicator

Lit while the keys are protected (Reset Key is disabled.).

3. DIP Switch

Use to change a setting. Refer to DIP Switch Settings for details.


5


# **Dimensions**


Note: All units are in millimeters unless otherwise indicated.

H7HP-A H7HP-C8









#### **Panel Cutouts**


Panel cutouts are as shown below (according to DIN43700).



**Note: 1.** The mounting panel thickness should be 1 to 6 mm.

**2.** Water resistance will be lost if Counters are mounted side-by-side.

### With Flush Mounting Bracket




# **Connections (Common)**

# **■ Input Connections**

Note: The following is common for all H7GP/H7HP models.


# **No-voltage Input (NPN Input Mode)**

# Reset, Count 1, Count 2, Start, and Gate Inputs



12 VDC (12 to 24 VDC)

#### Reset, Count 1, Count 2, Start, and Gate Inputs Specification




#### **Key Protection Inputs Specification**

 $\begin{array}{lll} \mbox{Short-circuit (ON) impedance:} & 1 \ \mbox{$k\Omega$ max.} \\ \mbox{Short-circuit (ON) residual voltage:} & 0.5 \ \mbox{VDC max.} \\ \mbox{Current flow for } 0 - \Omega \mbox{ short-circuit:} & \mbox{Approx. } 0.5 \ \mbox{mA} \\ \mbox{Open (OFF) impedance:} & 1 \ \mbox{$k\Omega$ max.} \\ \mbox{0.5 VDC max.} \\ \mbox{Approx. } 0.5 \ \mbox{mA} \\ \mbox{100 } \mbox{$k\Omega$ min.} \\ \mbox{100 } \mbox{$k\Omega$ min.} \\ \end{array}$ 

Note: Two-wired sensors cannot be used.

# **Voltage Input (PNP Input Mode)**

# Reset, Count 1, Count 2, Start, and Gate Inputs



#### Reset, Count 1, Count 2, Start, and Gate Inputs Specification

# **Safety Precautions (Common)**

Refer to Safety Precautions for All Counters.

Note: The following is common for all H7GP/H7HP models.

### / CAUTION

This may occasionally cause electric shock, fire, or malfunction. Never disassemble, repair, or modify the H7GP/H7HP.

This may occasionally cause electric shock, fire, or malfunction. Do not allow metal fragments or lead wire scraps to fall inside the H7GP/H7HP.

# ■ Precautions for Safe Use

Observe the following items to ensure the safe use of this product.


### **Environmental Precautions**

- Store the H7GP/H7HP within the specified ratings. If the H7GP/H7HP has been stored at temperatures –10°C or lower, let it stand for 3 hours or longer at room temperature before turning ON the power supply.
- Use the H7GP/H7HP within the specified ratings for operating temperature and humidity.
- Do not operate the H7GP/H7HP in locations subject to sudden or extreme changes in temperature, or locations where high humidity may result in condensation.
- Do not use the H7GP/H7HP in locations subject to vibrations or shock. Extended use in such locations may result in damage due to stress.
- Do not use the H7GP/H7HP in locations subject to excessive dust, corrosive gas, or direct sunlight.
- Install the H7GP/H7HP well away from any sources of static electricity, such as pipes transporting molding materials, powders, or liquids.
- The H7GP/H7HP is not waterproof or oil resistant.
   Do not use it in locations subject to water or oil.
- The life expectancy of internal components may be reduced if the H7GP/H7HP is mounted side-by-side.
- Do not use organic solvents (such as paint thinner or benzine), strong alkaline, or strong acids because they will damage the external finish.

#### **Usage Precautions**

- Install a switch or circuit breaker that allows the operator to immediately turn OFF the power, and label it to clearly indicate its function.
- Be sure to wire the terminals correctly.
- Do not install input lines in the same duct or conduit as power supply or other high-voltage lines. Doing so may result in malfunction due to noise. Separate the input lines from highvoltage lines.
- Internal elements may be destroyed if a voltage outside the rated voltage is applied.
- Maintain voltage fluctuations in the power supply within the specified range.
- Use a switch, relay, or other contact so that the rated power supply voltage will be reached within 0.1 s. If the power supply voltage is not reached quickly enough, the H7GP/H7HP may malfunction or outputs may be unstable.


 Although the H7GP/H7HP power supply (primary side) is isolated from control circuits (secondary side) by a transformer, the primary and secondary sides of the transformer are linked by a capacitor, making it possible for high-frequency components to leak to the secondary side. Take adequate precautions against electrical shock. Do not connect input circuits to exposed parts (such as the machine body) and be sure that the power supply is turned off before wiring.



# **Flush Mounting**

The panel surface is water-resistive (conforming to NEMA 4 and IP66). In order to prevent the internal circuit from water penetration through the space between the counter and operating panel, attach a rubber packing between the counter and operating panel and secure the rubber packing with the Y92F-3 $\square$  flush-mounting adaptor.

Be sure the rubber packing is installed in the correct direction. The wider portion must be facing the panel when installed, as shown in the following illustration. Using a flat-head screwdriver, press in the Mounting Adapter until it cannot be pressed in any further in order to ensure water-resistive performance.



### Other


Oil resistance is not applicable to all types of oil. Be sure to test any specific oils before actual application.

# **■** Precaution for Correct Use

# **Power Supplies**

When turning the power ON and OFF, input signal reception is possible, unstable, or impossible as shown in the diagram below.

Apply the power supply voltage through a relay or switch in such a way that the voltage reaches a fixed value immediately.



# **Self-diagnostic Function**


The following displays will appear if an error occurs.

Display	Error	Correction
	Less than –99999 (H7HP, 6-digit model) Less than –9999999 (H7HP, 8-digit model)	Press RST Key or reset input
E I	CPU	Press RST Key or turn
E2	Memory	power OFF and then ON


# Labels

Unit labels are included with the H7GP/H7HP and DIP switch labels are included with the H7HP. Attach these labels as shown in the following illustrations.

### **Unit Labels**



### **Н7НР**



# **DIP Switch Labels**

### H7HP



ALL DIMENSIONS SHOWN ARE IN MILLIMETERS.

To convert millimeters into inches, multiply by 0.03937. To convert grams into ounces, multiply by 0.03527.

In the interest of product improvement, specifications are subject to change without notice.

#### Read and Understand This Catalog

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments

#### Warranty and Limitations of Liability

#### WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

#### LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY.

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

### **Application Considerations**

#### **SUITABILITY FOR USE**

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

# PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

### **Disclaimers**

#### **CHANGE IN SPECIFICATIONS**

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

### **DIMENSIONS AND WEIGHTS**

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

#### PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

#### **ERRORS AND OMISSIONS**

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

2012.8

In the interest of product improvement, specifications are subject to change without notice.

