

Installation Instructions

■ Introduction

Thank you for purchasing Setting/monitoring tools for the C Controller module (SW4PVC-CCPU-E).

This document explains how to install and uninstall. Please read carefully before installing the product to your personal computer.

Installation

Install Setting/monitoring tools for the C Controller module to the personal computer.

■ Confirm before installation

- Log on to the personal computer as a user having the "Administrator" (computer administration) privilege.
- Close all the applications running under Microsoft® Windows® Operating System before installation. If the product is installed while other applications are running, it may not operate normally.

1. Insert the CD-ROM to the CD-ROM drive. Double click the "setup.exe" file on the CD-ROM.
2. Following the on-screen instructions, select or enter the necessary information.

Point

For precautions on installation, refer to Setting/Monitoring Tools for the C Controller Module Operating Manual.

■ Operating Environment

Item	Contents
Personal computer main body	Windows® supported personal computer
CPU	Intel®Core™2 Duo Processor 2GHz or more
Required memory	Recommended 1GB or more
Available hard disk capacity	When installing: HDD available capacity is 2.7GB or more. When operating: Virtual memory available capacity is 512MB or more.
Disk drive	CD-ROM supported disk drive
Monitor	Resolution 1024 x 768 pixels or higher
OS (Japanese version or English version)	Microsoft® Windows® 8.1 Operating System Microsoft® Windows® 8.1 Pro Operating System Microsoft® Windows® 8.1 Enterprise Operating System Microsoft® Windows® 8 Operating System Microsoft® Windows® 8 Pro Operating System Microsoft® Windows® 8 Enterprise Operating System Microsoft® Windows® 7 Starter Operating System Microsoft® Windows® 7 Home Premium Operating System Microsoft® Windows® 7 Professional Operating System Microsoft® Windows® 7 Ultimate Operating System Microsoft® Windows® 7 Enterprise Operating System Microsoft® Windows Vista® Home Basic Operating System Microsoft® Windows Vista® Home Premium Operating System Microsoft® Windows Vista® Business Operating System Microsoft® Windows Vista® Ultimate Operating System Microsoft® Windows Vista® Enterprise Operating System Microsoft® Windows® XP Professional, Service Pack 2 or later Microsoft® Windows® XP Home Edition, Service Pack 2 or later
Communication interface (CPU connected directly)	USB port Ethernet port

⚠ Notice

- Reprinting or reproducing the part or all of the contents of this document in any form for any purpose without the permission of Mitsubishi Electric Corporation is strictly forbidden.
- Although we have made the utmost effort to follow the revisions of the software and hardware, in some cases, unsynchronized matter may occur.
- The information in this document may be subject to change without notice.

Precautions

- If .NET Framework 2.0 and Windows Installer 3.0 are not installed to the personal computer to which Setting/monitoring tools for the C Controller module is to be installed, approximately 350MB of memory is required in the system drive to install them.
- For Windows® 8 and Windows® 8.1, if .NET Framework 3.5 (including .NET 2.0 and 3.0) is invalid on the personal computer to which Setting/monitoring tools for the C Controller module is to be installed, it needs to be valid.
- The following functions cannot be used when the computer is running under Windows® XP, Windows Vista®, Windows® 7, Windows® 8 or Windows® 8.1. This product may not perform properly, when these functions are used.
 - Activating the application with Windows® compatible mode.
 - Simplified user switch-over
 - Remote desktop
 - Large font size (Advanced setting of Display Properties)
 - DPI setting other than 100% (set the size of text and illustration other than [smaller-100%])
 - 64-bit edition*1
 - Windows XP Mode
 - Windows Touch or Touch
 - Modern UI
 - Client Hyper-V

*1 :Supported by Windows® 7, Windows® 8 and Windows® 8.1.
- Use the product as a user having a privilege higher than 'Standard user' or 'Administrator' for Windows Vista®, Windows® 7, Windows® 8, and Windows® 8.1.
- The screens of this product may not perform properly when multi-display is set on Display Properties.
- For Window® 8 or Windows® 8.1, set the screen resolution higher than 1152 x 864 pixels.

■ Product Makeup

Model name	Product name	Quantity
SW4PVC-CCPU-E (English version package) (Standard license product)	Setting/Monitoring Tools for the C Controller Module (CD-ROM)	1
	Installation Instructions (This document)	1
	End-user software license agreement	1
	Software registration notice	1
	License Certificate	1
	Industrial development tool purchasing form Development Tools: Workbench Node lock License Version Number: 3.2	1

Acknowledgements

- We do not guarantee those commercially available Microsoft® Windows® Operating System products that are introduced in this manual.
- This software's copyright is owned by Mitsubishi Electric Corporation.
- This software needs to be purchased one license per computer.
- This product (including manual) can be used under the Software License Agreement only.
- We do not take any responsibilities for the consequences of operating this product (including manual).

Installation of USB driver

In order to communicate with a C Controller module via USB, a USB driver needs to be installed.

For a USB driver installation procedure, refer to Setting/Monitoring Tools for the C Controller Module Operating Manual.

Uninstallation

Delete Setting/Monitoring Tools for the C Controller Module from the personal computer.

- 1. Uninstall Setting/Monitoring Tools for the C Controller Module from the control panel of Windows®.**

Microsoft, Windows, Windows Vista are trademarks or registered trademarks of Microsoft Corporation in the United States and other countries.
Intel Core 2 Duo is trademark or registered trademark of Intel Corporation in the United States and other countries.
Ethernet is a trademark or registered trademark of Xerox Corporation.
All other company names and product names used in this document are trademarks or registered trademarks of their respective companies.