


Option Function Board GT11-50FNB

The GT11-50FNB option function board is required for using the recipe function with the GT1155-QSBD or GT1150-QLBD (hereinafter called GOT).

1. External Dimensions and Part names




- 1) Lever for removal 2) Groove for reverse installation protection
3) Connector for connecting GOT

2. Mounting Precautions

Do not keep the option function board in a floated or inclined status.

Cross sectional view (with option function board installed)



For installation method of this product or cautions of use, refer to the manual of the GT11 main unit offered separately.



April 2015
JY997D14401D




Made in Japan

MITSUBISHI ELECTRIC CORPORATION

3. Installing and Removing


Be sure to shut off all phases of the external power supply used by the system before mounting or removing the option function board on to/from the GOT.

Removing



Pinch the lever with fingers and pull-up it vertically to remove the dummy cover.

Installing



Push-down the option function board by approximately 0.5mm with fingers along the groove for reverse installation protection.